

CIBA/26-27/298



अनुबंध क्रमांक | Contract No: GEMC-51168777258249

अनुबंध तिथि | Generated Date : 31-Jul-2026

बोली/आरए/पीबीपी संख्या | Bid/RA/PBP No.: GEM/2026/B/7617939

खरीद का माध्यम | Procurement Mode: Bid

संगठन विवरण Organisation Details		खरीदार विवरण Buyer Details					
प्रकार Type :	Central Autonomous	पद Designation :	Idc				
मंत्रालय Ministry :	Ministry of Agriculture and Farmers Welfare	संपर्क नंबर Contact No. :	044-24610565-338				
विभाग Department :	Department of Agricultural Research and Education (DARE)	ईमेल आईडी Email ID :	solin.s@icar.org.in				
संगठन का नाम Organisation Name :	Indian Council of Agricultural Research (ICAR)	जीएसटीआईएन GSTIN :	33AAAAH1830P1ZQ				
कार्यालय क्षेत्र Office Zone :	Central Institute Of Brackishwater Aquaculture	पता Address :	NO.75, SANTHOME HIGH ROAD, RAJA ANNAMALAIPURAM, CHENNAI, Chennai, TAMIL NADU-600028, India				
वित्तीय स्वीकृति विवरण Financial Approval Detail		भुगतान प्राधिकरण विवरण Paying Authority Details					
आईएफडी सहमति IFD Concurrence :	No	Role:	BUYER				
प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval:	THE DIRECTOR	भुगतान का तरीका Payment Mode:	Offline				
वित्तीय अनुमोदन का पदनाम Designation of Financial Approval:	THE DIRECTOR	पद Designation :	Idc				
		ईमेल आईडी Email ID :	solin.s@icar.org.in				
		जीएसटीआईएन GSTIN :	33AAAAH1830P1ZQ				
		पता Address:	NO.75, SANTHOME HIGH ROAD, RAJA ANNAMALAIPURAM, CHENNAI, Chennai, TAMIL NADU-600028, India				
विक्रेता विवरण Seller Details							
जेम विक्रेता आईडी GeM Seller ID :	2C95180000099842						
कंपनी का नाम Company Name :	Electro Equipments						
संपर्क नंबर Contact No. :	09997722774						
ईमेल आईडी Email ID :	manish@electroequipments.com						
पता Address :	20-23, BHAGWANPUR, RAIPUR SAHKARI AUDYOGIC KSHETRA, Haridwar, UTTARAKHAND-247661, :						
एमएसएमई पंजीकरण संख्या MSME Registration number :	UDYAM-UK-06-0003663						
जीएसटीआईएन GSTIN:	05AACFE1653M2ZH (B) , (R)						
खरीदार द्वारा मूल्यांकित एमआईआई स्थिति MI Status as evaluated by buyer :	Verified						
खरीदार द्वारा सत्यापित एमएसएमई स्थिति MSME Status as verified by buyer :	Verified						
एमएसई सामाजिक श्रेणी MSE Social Category :	General						
एमएसई लिंग श्रेणी MSE Gender :	Male						
*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा GST / Tax invoice to be raised in the name of - Consignee							
वितरण निर्देश Delivery Instructions : NA							
उत्पाद विवरण Product Details							
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)	
1	उत्पाद का नाम Product Name : Koel Green Electro Power Generator- DG set of 58.5 AMF Control Panel ब्रांड Brand : Koel Green Electro ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Diesel Power Generator (up to 900 KVA) (Q2) मॉडल Model: 4R810FTA-4G1 एनएसएन कोड HS Code: 8502 उद्गम देश Country Of Origin: India	1	pieces	1,090,600	NA	1,090,600	
कुल ऑर्डर मूल्य Total Order Value (in INR)						1,090,600	
परिप्रेषी विवरण Consignee Detail							
						दिनांक के बाद डिलीवरी शुरू	वितरण पूरा कब तक करना है।

क्र.सं. S.No	प्रेषणी Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	करना है Delivery Start After	Delivery To Be Completed By
1	पद Designation :- ईमेल आईडी Email ID : aravind.pillai@icar.gov.in संपर्क Contact :- जीएसटीआईएन GSTIN :- पता Address : Muttukadu Experimental Station, Kovalam Post, Muttukadu, Chennai-613112, Kanchipuram, TAMIL NADU-603112, India	Koel Green Electro Power Generator- DG set of 58.5 AMF Control Panel		1	31-Jul-2026	30-Aug-2026
Product Specification for Koel Green Electro Power Generator- DG set of 58.5 AMF Control Panel						
विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value				
Installation Configuration	Power Generator Installation Configurations as per CPWD General Specifications for Electrical Works – Part VII (DG Set)	Fixed (Power Generators are permanently installed)"				
Ratings	Nominal Rated Capacity (in kVA)	58.5				
	Number of Phase	Three Phase				
Engine	Make of Engine	KIRLOSKAR/KOEL GREEN				
	Model Number of Engine	4R810ETA 4G1				
	Capacity of Engine (cc)	3240				
	Rated Engine Power (kWm)	110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxiliary power Consumption by the Power generator) × Power factor(0.8) / Alternator efficiency				
	Type of Engine Cooling	Liquid Cooled				
	Type of Governor	Electronic				
	Number of Cylinders	4				
	Number of Strokes	4				
	Rated Engine Speed (in RPM)	1500				
	Type of Fuel	High Speed Diesel (HSD)				
	Overload Capacity	Engine is capable of delivering an output of 10% in excess of rated KVA for a period of one hour in any period of 12 hours continuous running				
	Specific Fuel Consumption (in gram/kWh)	200 to 265				
	Starting Voltage (in volt)	12				
	Salient Features of Engine [Hint: Products matching all selected values will be displayed; For example, if both 'Turbo Charged Engine' and 'Direct Injection Fuel System' are selected, product that include both options will be shown]	Turbo Charged Engine,Direct injection Fuel System				
	Governor Class	A2 or better				
	Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient)	15				
	Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient)	15 second				
	Maximum Change of Speed as a Percentage of Rated Speed on suddenly	5				

Governing Class	taking-off the rated load (Permanent)	
	Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient)	4
	Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load (Transient)	5 second
	Maximum Change of Speed as a Percentage of Rated Speed on a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent)	1.5
Alternator	AC Generator (Alternator) Make	KIRLOSKAR/KOEL GREEN
	AC Generator (Alternator) Model Number	KIRLOSKAR/KOEL GREEN
	Alternator Voltage Rating	415 Volt
	Rating of AC Generator (KVA)	58.5
	Power Factor of AC Generator	0.8
	Efficiency at Rated Power Factor at 75% of Full Load	92.6 percent
	Conformity to Indian Standard For Alternator	Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	Type of Alternator	Brushless
	Voltage Regulation Grade	VG 3
	Alternator IP (Ingress Protection) Rating	IP 23
	Class of Insulation	H
	Salient Features of Alternator [Hint: Products matching all selected values will be displayed; For example, if both 'space heater' and 'Bearing Temperature Detectors (BTD)' are selected, product that include both options will be shown]	NA
	Type of Control Panel	AMF Control Panel
	Control Panel Location	Outside the Canopy
	IP (Ingress Protection) Rating of Control Panel	IP 53
	Display Meters in Control Panel (with Appropriate Rating and Accuracy Class) - Included in Scope of Supply	Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor)
	Other Devices in Control Panel (with Appropriate Rating) - Included in Scope of Supply	Required switches and cutout, Contactor, Battery charger

Control Panel	Display Parameters/Features [Hint:Products matching all selected values will be displayed; For example, if both 'Engine Speed' and 'Lube oil pressure' are selected, product that include both options will be shown]	Engine Speed,Lube oil pressure,Coolant/cylinder head Temperature,Engine running hours,Engine battery voltage,Engine Running status,Generator Voltage (Ph-Ph),Generator Voltage (Ph-N),Generator Current (R, Y, B),Generator apparent Power (kVA),Generator active Power (kW),Powerfactor,Frequency,Fuel level,Event log,Control supply Voltage
	Indicators [Hint:Products matching all selected values will be displayed; For example, if both 'Over speed' and 'Low fuel level' are selected, product that include both options will be shown]	Low Lube oil pressure,High water / coolant / cylinder head temperature,Low fuel level,Over speed
	Audio Alarm [Hint:Products matching all selected values will be displayed; For example, if both 'Over speed' and 'Low fuel level' are selected, product that include both options will be shown]	Low Lube oil pressure,High water / coolant / cylinder head temperature,Low fuel level,Over speed
Acoustic Enclosure	Acoustic Enclosure - Included in Scope of Supply	Yes, Power Generator supplied with Acoustic Enclosure
	Sheet Thickness (in mm)	1.6
	Thickness of Insulation	25 millimeter
	Density of Insulation (in kg/cubic meter)	28
	Noise Level at 1 Meter (in dB)	75
Fuel Tank	Fuel Tank Capacity	165 liter
	Number of Fuel Tank	1
	Fuel Tank Fabricated Material	M.S Sheet
	Fuel Tank Sheet Material Thickness (in mm)	2
	Fuel Tank Features	Fuel Tank capacity is sufficient for 8 hrs of running at full load
Battery	Battery Type	"Low Maintenance free to 15: 14257 for high cranking performance"
	Battery Capacity (in Ah)	100
	Number of Batteries	1
Salient Features	Salient Features of Power Generator	Glass window on Accoustic Enclosure in front of the Control Panel,Emergency Stop outside the Accoustic Enclosure
	Additional Features	NA
Trailer	Availability of Trailer	NA for Fixed/Skid Mounted Power Generator
	Pay Load of the Trailer	0 kilogram
	Number of Axles	0
	Number of Wheels	'NA' for without trailer
	Wheel Tyre Size	0 inch
	Brake Mechanism	NA for Fixed/Skid Mounted Power Generator
	Trailer Complying to CMVR act and Regulation	NA for Fixed/Skid Mounted Power Generator
	Maximum Permissible Speed of Trailer (in Km/hr) [Hint: Please write '0' if Not Applicable]	0

General Technical Requirements (GTR) / Commissioning	Trailer Unladen Weight	0 kilogram
	Trailer Overall Length	0 millimeter
	Gross Towing Weight (including Power Generator)	0 kilogram
	Salient Features of Trailer	NA
	General Technical Requirements (GTR) / Commissioning (Part-1)	a) Power Generator shall be complete with Diesel Engine, Alternator and AMF/MANUAL Control Panel along with Acoustic Enclosure. Diesel engine and alternator shall be closely coupled or provided with flexible coupling and mounted on a base plate / M.S. frame of robust in construction.
	General Technical Requirements (GTR) / Commissioning (Part-2)	b) Anti-Vibration mountings shall be provided for complete Power Generator in case of flexible coupling. In case of direct coupling Anti-Vibration mountings shall be provided for the Engine as well as the alternator.
	General Technical Requirements (GTR) / Commissioning (Part-3)	c) Power Generator should have protection against under voltage, over voltage, under frequency, over frequency, low battery voltage, over current, earth-fault, short circuit, phase sequence change etc.
	General Technical Requirements (GTR) / Commissioning (Part-4)	d) Automatic Mains Failure (AMF) control panel, where applicable, shall be able to start up the Power Generator and transfer the load on to the Power Generator on mains failure without requiring any human intervention. Similarly on restoration of mains supply, it shall be able to transfer the load to mains supply and switch off the Power Generator automatically.
	General Technical Requirements (GTR) / Commissioning (Part-5)	e) Control Panel (Manual / AMF), where applicable, shall be equipped with suitable Voltmeter, Ammeter, Frequency meter, power factor meter (these items can be alternatively supplied in one multifunctional digital display meter), battery charger, indicators, various switches and cutout / MCB / MCCB / Contactor / Circuit breaker for the DG output of appropriate rating and accuracy class as per trade practice for better utility.
	General Technical Requirements (GTR) / Commissioning (Part-6)	f) Supply and installation of a change-over Switch / MCCB of suitable rating for Power Generator with manual control panel, where applicable, is inclusive in the scope of supply.
	General Technical Requirements (GTR) / Commissioning (Part-7)	g) Acoustic Enclosure shall be made of Pre-treated and Powder coated CRCA Sheet. The sheet shall be Pre-treated and Powder coated with weather-proof paint. The Acoustic Enclosure shall be vermin proof. The enclosure shall accommodate the (daily service) fuel tank of the Power Generator to make the system compact.
	General Technical Requirements (GTR) / Commissioning (Part-8)	h) Power Generators shall meet the requirements of Environmental (Protection) Rules 1986 as laid down by Min. of Environment & Forests read with GSR 371 (E) dated 17.5.2002, GSR 520(E) dated 1.7.2003, No.448 (E) dated 12.07.2004, GSR 771(E) dated 11.12.2013 GSR 232(E) dated 31.03.2014, Gazette Notification No.167 dated. 31.03.2014 and Gazette Notification No. 578 dated. 11.11.2014 in respect of noise and emission norms. The latest amendments to above GSRs shall be applicable as and when amended by Ministry of Environment and Forest.
	General Technical Requirements (GTR) / Commissioning (Part-9)	i) Standard set of tools consisting of a set of 3 spanners, one screw driver, one standard plier and one nose plier of appropriate size shall be provided along with each Power Generator.
	General Technical Requirements (GTR) / Commissioning (Part-10)	j) Supply of Fuel tank of suitable capacity, sufficient for minimum 8 hours running/990 liters(whichever is lower) the Power Generator, is inclusive in the scope of supply. Fuel Tank shall be complete with fuel piping (between fuel tank and diesel engine), valves, level indications and all standard accessories. MS pipes, heavy class of suitable dia conforming to IS 1239 (Part-1) - latest shall be used for fuel piping.
	General Technical Requirements (GTR) / Commissioning (Part-11)	Buyer's Responsibilities: i. Mains ACB for AMF operation shall be provided by the buyer for DG set rating above 600 KVA and above. For DG set other ratings seller shall provide mains and DG contactor/breaker. ii. Exhaust piping, extra civil work, distribution board shall be provided by the buyer. iii. Consumables such as filters, lube oil at the time of servicing during warranty period shall be provided by the buyer. iv. Obtaining necessary approvals, if any, is the responsibility of the buyer.
	Above General Technical Requirements (GTR) / Commissioning have been seen, read, understood and agreed to comply	Yes
Installation	Installation Requirement	with installation - inclusive in the scope of supply
	Scope of installation for diesel generating set when offered by the vendor - inclusive in the scope of supply (Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of RCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.
	Scope of installation for diesel generating set when offered by the vendor - inclusive in the scope of supply (Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase.
	Scope of installation for	d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 &

Requirement	diesel generating set when offered by the vendor - inclusive in the scope of supply (Part-3)	75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA
	Scope of installation for diesel generating set when offered by the vendor - inclusive in the scope of supply (Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Neutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f) The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of Installation for the Diesel Generating Set, when offered by the vendor, has been seen, read, understood, and agreed to Comply	Yes
Warranty/Services	Standard Warranty on Complete Power Generator / DG Set	24 month
	Warranty (in Running Hours)	2500 hour
	Number of Preventive Maintenance Visits Offered in an Year During Warranty Period (Supply of all consumables is the buyer's responsibility)	2
	Response Time to Attend the Complaint During Warranty	7 day
	Time Duration For Repairing/Replace the Defect during Warranty	30 day
Test Reports	Type of lab which carried out test of complete product to prove the conformity of product specification	Certificates required as per CPCB
	Test Report Available For (Test/approval)	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications
	Agree to provide all relevant documents test report/supporting documents /reports etc to the buyer at the time of bidding or on demand	YES

Annual maintenance charges for Koel Green Electro Power Generator- DG set of 58.5 AMF Control Panel

सेवा वर्ष Service Year	एएमसी प्रतिशत AMC Percentage	एएमसी राशि AMC Amount	एएमसी आवृत्ति AMC Frequency
AMC charges for 1st year after warranty period in % of cost of equipment	3.25%	35444.50	Quarterly
AMC charges for 2nd year after warranty period in % of cost of equipment	3.38%	36862.28	Quarterly
AMC charges for 3rd year after warranty period in % of cost of equipment	3.51%	38280.06	Quarterly
AMC charges for 4th year after warranty period in % of cost of equipment	3.64%	39697.84	Quarterly
AMC charges for 5th year after warranty period in % of cost of equipment	3.77%	41115.62	Quarterly
AMC charges for 6 year after warranty period in % of cost of equipment	3.90%	42533.40	Quarterly
AMC charges for 7 year after warranty period in % of cost of equipment	4.02%	43842.12	Quarterly
AMC charges for 8 year after warranty period in % of cost of equipment	4.15%	45259.90	Quarterly
AMC charges for 9 year after warranty period in % of cost of equipment	4.28%	46677.68	Quarterly
AMC charges for 10 year after warranty period in % of cost of equipment	4.41%	48095.46	Quarterly

एएमसी के लिए अतिरिक्त खंड | Additional Clauses for AMC

1. AMC charges to be indicated as percentage of cost of Product/Equipment quoted for each year after the warranty period.
2. GST shall be included in the AMC Charges quoted.
3. The AMC functionality shall be available in bid only and no direct RA shall be applicable. In case of bid to RA decrement rules shall be applicable on total price inclusive of AMC charges.
- 3.1 Buyer shall indicate number of years of warranty by selecting option of 1- 10 Years available in the field depending on warranty parameter applicable in category parameters for the equipment. The Seller while participating in Bid/RA will get fields to indicate AMC charges as percentage depending on number of years of AMC selected by Buyer. The following shall be applicable If 5 year AMC selected.
 - 3.1.1 AMC charges for first year after warranty period – Percentage to be indicated- A1.
 - 3.1.2 AMC charges for second year after warranty period – Percentage to be indicated A2.
 - 3.1.3 AMC charges for third year after warranty period – Percentage to be indicated A3.
 - 3.1.4 AMC charges for fourth year after warranty period – Percentage amount to be indicated A4.
 - 3.1.5 AMC charges for 5th year after warranty period – Percentage to be indicated A5.
- 3.2 The calculation of AMC Charges shall take in to account of number of years of warranty and duration of AMC as specified while creating bid.
- 3.3 AMC charges to be indicated for each subsequent year should be same or higher than preceding year.
- 3.4 The AMC charges shall be offered within range of 3 to 50% of cost of equipment.
4. Since AMC charges are to be paid only later for each year during AMC period , applicable performance guarantee amount after placement of contract shall be based on the cost of product/equipment and not on basis of cost of equipment along with AMC Charges.
5. Performance bank guarantee applicable for AMC is to be submitted at start of the AMC and shall be applicable as 2.5% on the total contract value including AMC Charges The PBG submitted after award of contract shall be released only after new PBG for the AMC period is submitted and accepted by buyer/consignee after due verification. Bank guarantee for AMC is to remain valid till completion of AMC period plus one year .The bank guarantee for AMC shall be submitted to buyer directly.
6. In case of splitting of quantity product/equipment cost and AMC charges offered by L-1 in the evaluated cost shall be matched by higher quoting eligible bidders on one to one basis .The equipment cost shall be matched and AMC charges shall be matched year to year.
7. The AMC Contract shall be an offline contract to be handled by buyer. The payment of AMC will be made on AMC frequency (as indicated above) basis after satisfactory completion of said period, duly certified by end user and scope of AMC will be as per para 1 above.

ईपीबीजी विवरण | ePBG Detail

सलाहकार बैंक Advisory Bank :	State Bank of India
ईपीबीजी प्रतिशत (%) ePBG Percentage(%):	3.00
बोली लगाने वाले को बोली के नियमों और शर्तों के अनुसार लागू ईपीबीजी प्रस्तुत करना होगा The bidder shall furnish ePBG as applicable as per bid's terms and conditions	

नियम और शर्तें | Terms and Conditions

1. General Terms and Conditions-

- 1.1 This contract is governed by the General Terms and Conditions, conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable
- 1.3 All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and
- All operative provisions of the erstwhile Labour Laws until their complete substitution.

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

2. Buyer Added Bid Specific Terms and Conditions-

2.1 Generic:

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery

period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be (Increased quantity : Original quantity) × Original delivery period (in days), subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2.2 Generic

Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

2.3 Generic

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

Rajiv Gandhi Centre for Aquaculture Seabass Hatchery Project & Mud Crab Hatchery
Koozhaiyar Road, Thoduvali
Thirumullaivasal,
Sirkali Taluk
Mayiladuthurai 609113

2.4 Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

2.5 Generic

End User Certificate: Wherever Bidders are insisting for End User Certificate from the Buyer, same shall be provided in Buyer's standard format only.

2.6 Generic

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

2.7 Generic

Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

2.8 Scope of Supply:

Scope of supply (Bid price to include all cost components): Supply Installation Testing and Commissioning of Goods

2.9 OEM

IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

2.10 Service & Support:

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

2.11 Service & Support:

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

2.12 Warranty:

Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 10 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

2.13 Buyer Added Bid Specific ATC:

Buyer uploaded ATC document [Click here to view the file.](#)

2.14 Forms of EMD and PBG:

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

ICAR UNIT CIBA
payable at
CIBA CHENNAI

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

Note:

1. Sellers are required to raise invoices online as per the contract terms on GeM portal. Timely invoice submission is mandatory for compliances, smooth payment processing, and will also contribute to improving their ratings.

नोट: यह सिस्टम जनरेटड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

Dr. K. P. Kumaraguru Vasagam

File no - 5-5/26-27/ST

Gmp no - 436533

Note # 17

Date - 30/07/26

fund - MPEDA - RGICA
(4001/569)